

GOVT. OF ASSAM
OFFICE OF THE DIRECTOR,
FIRE AND EMERGENCY SERVICES, ASSAM, GUWAHATI.



SEE RULE - 18(2)
No. F&ES/FPW/18(XIV)/58-60/21
To,

F O R M - (G)

Dated Guwahati the 29/01/21

The Principal,
P.K.M. English Medium School,
Dhaligaon, Bongaigaon,
Dist:- Bongaigaon, Assam.

RENEWAL OF NO OBJECTION CERTIFICATE OF INBUILT FIRE FIGHTING/ FIRE PREVENTION AND MEANS OF ESCAPE MEASURES IN THE P.K.M. ENGLISH MEDIUM SCHOOL AT DHALIGAON, BONGAIGAON, DIST:- BONGAIGAON, ASSAM.

With reference to your completion report under No. NIL Dated 06.12.2020 and on the basis of the inspection report submitted by Response Team Commander, Amit Barman on the building as per description below at Dag No. 1354 Patta No. 132 Mouza Bongaigaon, (Place- Bongaigaon) in respect of implementation of Inbuilt Fire Fighting/ Fire Prevention/ means of escape measures as declared fit in respect of fire safety. The Fire & Emergency Services, Assam has No objection in its occupation /utilization for the purpose of SCHOOL subject to condition mentioned over leaf.

DETAILS OF APPROVED OCCUPATION:-

GROUND FLOOR: -

1. Floor area: -Block 'A'= 279.61 m² (Assam type),
Block 'B'= 139.41 m² (Assam type),
Block 'C'= 279.09 m² (RCC)
Block 'D'= 314.76 m² (RCC)

2. Purpose of utilization: -
For School Purpose.

SECOND FLOOR: -

1. Floor area: -Block 'C'= 388.01 m²
Block 'D'= 314.76 m²

2. Purpose of utilization: -
For School Purpose.

FOURTH FLOOR: -

1. Floor area: -Block 'C'= 388.01 m²

2. Purpose of utilization: -
For School Purpose.

FIRST FLOOR: -

1. Floor area: -Block 'C'= 388.01 m²
Block 'D'= 314.76 m²

2. Purpose of utilization: -
For School Purpose.


THIRD FLOOR: -


1. Floor area: -Block 'C'= 388.01 m²
Block 'D'= 314.76 m²

2. Purpose of utilization: -
For School Purpose.

Details of Fire Fighting measures found in working condition:

1. Hose Reel Hose system
2. Down Comer system
3. Manually Operated Electric Fire Alarm system
4. Fire Extinguishers- 20 Nos.
5. Terrace Water Tank
6. Fire Pump


Principal
PKM E.M. School, Dhaligaon
Bongaigaon, Assam


Manager
PKM E.M. School, Dhaligaon
Bongaigaon, Assam


Deputy Director,
for and on behalf of
Director of Fire and Emergency Services,
Assam, Guwahati.

(((2)))

NO. F&ES/FPW/ 13(XIV) 58-60/21 Dated Guwahati the 29/1/21

Copy to:-


1. The Deputy Commissioner, **Bongaigaon**, Assam for information and necessary action.
2. The Chairman, **Bongaigaon Municipal Board**, Assam for information and necessary action.
3. The Response Team Commander, **Bongaigaon F&ES Station**, for information.


Deputy Director,
for and on behalf of
Director of Fire and Emergency Services,
Assam, Guwahati.

CONDITION:-

1. The N.O.C. is valid up to: - **31.03.2022**
2. There should not be any change of Trade for which this License has been issued.
3. There should not be any structural change in the building either horizontally or vertically.
There should not also be any change in the existing arrangements.
4. The Fire Fighting equipments should be in serviceable condition at all time.
5. Water reservoir should always be kept full up to brim.
6. The entrance and exit and the water reservoir should always be free from any obstruction/ projection.
7. The N.O.C. is liable to be cancelled if the premises (for which the N.O.C. is granted) when inspected are not found conforming to the description and condition under which this N.O.C. is granted.

/
Deputy Director,
for and on behalf of
Director of Fire and Emergency Services,
Assam, Guwahati.



Principal
PKM E.M. School, Dhaligaon
Bongaigaon, Assam



Manager
PKM E.M. School, Dhaligaon
Bongaigaon, Assam